

Passive Fire Protection Installation

LPS 1531: ISSUE 1.0
CERTIFICATE OF CONFORMITY

Certificate No. 1066Pla0000044

This certificate is issued by the LPS 1531 approved company named in (1) of the schedule, for the client in (2) of the schedule, for the following premises:

Harland Building Services Ltd



Schedule

Prestige Fire Door Services Limited

1) Issuing Company

1066Pla

Company Certificate No.

We, being certified to LPS 1531 in respect of the installation and application of passive fire protection products, do certify that the installation or application was carried out in accordance with LPS 1531 "Requirements for the LPCB approval and listing of companies installing or applying passive fire protection products".

University College Hospital London

2) Client

P623

Contract Number

UCL Hospital

Contract Name

03 September 2015

Contract Completion Date

Jeremy French –Technical Director

Name, Position

Signature

Prestige Fire Door Services Ltd

For and on behalf of

03 September 2015

Issue date



Company Certificate
No. 1066Pla

bre

BF1296 Rev. 0.2
© BRE Global Ltd., 2014

LPS 1531: Issue 1.0

Certificate of Conformity

Certificate No. 1066Pla0000044

Schedule Continued:



LPS 1531: Issue 1.0

Certificate of Conformity

Certificate No. 1066Pla0000044

Schedule Continued:

Contract premises:
Harland Building Services Ltd

UCL Hospital

Contract Name

P623

Contract Number

Product manufacturer, product name, 3rd Party Approval (if approved), and fire performance

Scope of Works	Location
Rockwool Firepro System, 50mm ablative batt infill into existing FR bulkheads above double doors in 6 locations. To reinstate breaches in and around service penetrations, 120 minute rating. Between attenuvent and smoke damper. Third party approved LPCB cert no. 022b(5)	Basement link corridor: cross corridor assemblies overhead bulkheads and valve cupboard

Works not completed or excluded	Location



Company Certificate
No. 1066Pla

LPS 1531: Issue 1.0
Certificate No. 1066Pla0000044

Certificate of Conformity

Schedule Continued:

Works not completed or excluded	Location

Jeremy French – Technical Director

Name, Position



Signature

Prestige Fire Door Services Ltd

For and on behalf of

03 September 2015

Issue date

